



# License No. 18360 to mark a commodity with the Standards Mark

The Standards Institution of Israel (SII), in accordance with the powers vested in it by article 11(b) of the Standards law 1953, hereby grants permission to:

**Metal Press Export (1982) Ltd.**

4, Hamlacha St. ,Bat Yam ,Israel

to place the Standards Mark on the commodities covered by the standard:  
**Fire Safety In Buildings:fire Dampers.**

(list of types attached)

**These commodities are produced in conformity with the requirements of the  
Israel Standard No. 1001 Part 3 Edition April 2010**

This license has been granted subject to the terms of the Standards Regulation (standard mark and supervision sign) 1982, and the terms that the License Committee has determined, which constitute an integral part of this license. This license does not detract from any obligation, or other order, imposed by law on the abovementioned commodities

This certificate remains the property of SII. Its continued validity may be verified via scanning the barcode or via the SII website [www.sii.org.il](http://www.sii.org.il).

**This license is valid until 31/12/2026**

Date of License : 01/01/2026



R.N 510915887

Dr. Gilad Golub  
CEO



The standards Institution of Israel  
42 Chaim Levanon St,  
Tel-Aviv 6997701



## Annex A: License No. 18360

Factory: Metal Press Export (1982) Ltd.

Commodities: Fire Safety In Buildings: fire Dampers.

### Models:

1. 5030 POWER DAMPER WITH 4 SPRINGS AND A CABLE MOTOR UP TO 0.81.M'2
2. 5020 POWERED FIRE DAMPER WITH FUSE UP TO 0.73 M'2
3. 5020, 1.5 HOURS, SIZE 1X2
4. "5020" FIRE DAMPER 1,5-0 HORIZONTAL
5. 5020, fire shelf with fuse up to 0.475 msq Engine extension TF24, manufactured by BELINO

**This license is valid until 31/12/2026**

Date of License : 01/01/2026



R.N 510915887

Dr. Gilad Golub  
CEO



The standards Institution of Israel  
42 Chaim Levanon St,  
Tel-Aviv 6997701

# היתר מספר 18360 לסמן מצרך בתו תקן

מכון התקנים הישראלי, בתוקף סמכותו לפי סעיף 11(ב) לחוק התקנים התשי"ג 1953 מעניק בזה ל:

## מטלפרס יצוא (1982) בע"מ

המלאכה 4, אזור תעשיה, בת ים, ישראל

את הרשות לסמן בתו תקן את המצרכים שחל עליהם התקן שלהלן:

**בטיחות אש בבניינים: מדפי אש**

רשימת דגמים מצורפת

מצרכים אלה מיוצרים לפי דרישות התקן הישראלי ת"י 1001 חלק 3 מהדורה אפריל 2010

היתר זה ניתן בכפיפות לתנאים שבתקנות התקנים (תו-תקן וסימן השגחה), התשמ"ב 1982 ולתנאים שהחליטה עליהם ועדת ההיתרים, המהווים חלק בלתי נפרד מהיתר זה. היתר זה אינו גורע מכל חובה, או הוראה אחרת, המוטלת על פי דין על המצרכים הנ"ל. ההיתר הוא רכוש מת"י. לברור תוקף ההיתר ניתן לסרוק את הברקוד, או להיכנס לאתר מכון התקנים הישראלי [www.sii.org.il](http://www.sii.org.il)

**תוקף ההיתר עד יום 31/12/2026**

  
ד"ר גלעד גולוב  
מנכ"ל



פ. 510915887

תחילת תוקף היתר: 01/01/2026

עמוד 1 מתוך 2



מכון התקנים הישראלי



מכון התקנים הישראלי  
רחוב חיים לבנון 42,  
תל-אביב 6997701

# נספח א' להיתר: 18360 מפעל: מטלפרס יצוא (1982) בע"מ

מצרכים: בטיחות אש בבניינים: מדפי אש

## דגמים:

1. 5030:מדף אש סטאטי. דרגת עמידות באש 90 דקות.  
להתקנה בכיוון אנכי. עד 0.81 מ"ר
2. 5020:מדף אש סטאטי. דרגת עמידות באש 90 דקות.  
להתקנה בכיוון אנכי. עד 0.73 מ"ר
3. 5020:מדף אש סטאטי. דרגת עמידות באש 90 דקות.  
להתקנה בכיוון אנכי. עד 2 מ"ר
4. 5020:מדף אש סטאטי. דרגת עמידות באש 90 דקות.  
להתקנה בכיוון אופקי. עד 0.81 מ"ר.
5. 5020:מדף אש סטאטי. דרגת עמידות באש 90 דקות.  
להתקנה בכיוון אנכי. עד 0.475 מ"ר



תוקף ההיתר עד יום 31/12/2026

  
ד"ר גלעד גולוב  
מנכ"ל



פ.ח. 510915887

תחילת תוקף היתר: 01/01/2026



מכון התקנים הישראלי  
רחוב חיים לבנון 42,  
תל-אביב 6997701